

Public Drinking Water System

Laboratory Analysis Reporting Format

For Lead and Copper Tap Samples

CERTIFIED LABORATORY NAME: Sanders Laboratories, Inc.

HRS CERTIFICATION NUMBER: E84380

LABORATORY CONTACT:

PHONE NUMBER: 941-488-8103

Signature of Laboratory Official Reviewing Report:

Name (Print):

Date Signed:

TMA
TAMI BRIGHT
7/21/23

The attached sampling analytical results were submitted by the following public water system. Each sample container contained one liter of solution (+/- 100 ml). All samples were to the best of our knowledge taken properly by the following system and analyzed in accordance with the requirements listed on page 26560 of the June 7, 1999 Federal Register. Tap sampling dates were reported for each sample received.

PUBLIC WATER SYSTEM NAME: _____

MAILING ADDRESS: _____

SYSTEM TYPE (CIRCLE ONE): _____ CWS OR NTNC _____

IDENTIFICATION NUMBER (PWS-ID) _____

POPULATION SERVED: _____

SIGNATURE OF AUTHORIZED PWS REPRESENTATIVE:

SIGNATURE: _____

NAME (PRINT): _____

DATE: _____

DER/ACPHU REVIEWING OFFICIAL:

DATA SUBMITTAL (CHECK ONE)

SATISFACTORY() UNSATISFACTORY() NOT PROPERLY IDENTIFIED ()

Lead and Copper Tap Sample Analysis and Result Ranking

Reporting Format 62-550.730(4)(a)

System Name: North Port Utilities

Date Submitted to Lab: 06/21, 23, 27 - 2023

PWS-ID: 658-0651

Analysis Date: 06/26, 06/28, 07/01 - 2023

Laboratory Name: Pace Analytical

Lab Analysis method: EPA 200.8

Lab-ID: E83079

Lead or Copper (list one): Lead

Laboratory Contact Person:

Method Detection Limit: 0.00022 mg/L

Phone:


90th Percentile Value: 0.0015

A	RANK	ID NO.	LOCATION	TIER	LAB SAMPLE ID	DATE SITE SAMPLED	LEAD (mg/L)	COPPER (mg/L)
	1	48	3866 Corvette Ln		2306590-009	06/21/23	U 0.00022	
	2	58	5980 Spearman Cir		2306590-010	06/21/23	U 0.00022	
	3	36	4686 Blueridge St		2306590-016	06/13/23	U 0.00022	
	4	30	5383 Kismet Ter		2306590-022	06/14/23	U 0.00022	
	5	60	2650 Colonade Ln		2306590-025	06/22/23	U 0.00022	
	6	76	8144 Trionfo Ave		2306590-033	06/22/23	U 0.00022	
	7	65	6541 Kenwood Dr		2306590-034	06/23/23	U 0.00022	
	8	33	7583 Darlene St		2306590-027	06/20/23	I 0.00027	
	9	31	7554 Berwick St		2306590-019	06/13/23	I 0.00028	
	10	15	4065 Vermont Ln		2306590-003	06/15/23	I 0.00033	
	11	3	5329 Ansonia Terr		2306590-017	06/12/23	I 0.00036	
	12	55	5922 Hobhill Ave		2306590-037	06/23/23	I 0.00037	
	13	47	3671 S Cranberry Blvd		2306590-029	06/23/23	I 0.00041	
	14	2	7590 Lyncrest St		2306590-004	06/13/23	I 0.00042	
	15	62	6690 Landover Ter		2306590-008	06/21/23	I 0.00042	
	16	77	6795 Appomattox		2306590-023	06/23/23	I 0.00042	
	17	11	4396 Blitzzen Ter		2306590-001	06/13/23	I 0.00052	
	18	66	6220 Hoffman St		2306590-031	06/21/23	I 0.00054	
	19	18	7195 Arab Ct		2306590-013	06/12/23	I 0.00060	
	20	1	7531 Berwick St		2306590-024	06/19/23	I 0.00062	

CERTIFICATION. The tap samples used for lead and copper analyses were submitted by the above PWS. Each sample container had one liter of solution (± 100 mL). All samples were taken properly by the above system and analyzed in accordance with the requirements in subsection 62-550.550(1), F.A.C. The sampling dates were reported for each sample received. I hereby certify that all data submitted are correct.

SIGNATURE OF AUTHORIZED LABORATORY REPRESENTATIVE: _____ 

NAME (Please Print): _____ Tami Bright _____

TITLE and DATE: _____ Office Manager _____ 

Lead and Copper Tap Sample Analysis and Result Ranking

Reporting Format 62-550.730(4)(a)

System Name: North Port Utilities

Date Submitted to Lab: 06/21, 23, 27 - 2023

PWS-ID: 658-0651

Analysis Date: 06/26, 06/28, 07/01 - 2023

Laboratory Name: Pace Analytical

Lab Analysis method: EPA 200.8

Lab-ID: E83079

Lead or Copper (list one): Copper

Laboratory Contact Person:

Method Detection Limit: 0.00093 mg/L

Phone:

90th Percentile Value: 0.084

A	RANK	ID NO.	LOCATION	TIER	LAB SAMPLE ID	DATE SITE SAMPLED	LEAD (mg/L)	COPPER (mg/L)
	1	65	6541 Kenwood Dr		236590-034	06/23/23		0.0082
	2	60	2650 Colonade Ln		236590-025	06/22/23		0.0085
	3	48	3866 Corvette Ln		236590-009	06/21/23		0.0093
	4	76	8144 Trionfo Ave		236590-033	06/22/23		0.0093
	5	11	4396 Blitzen Ter		236590-001	06/13/23		0.0095
	6	58	5980 Spearman Cir		236590-010	06/21/23		0.012
	7	36	4686 Blueridge St		236590-016	06/13/23		0.014
	8	18	7195 Arab Ct		236590-013	06/12/23		0.020
	9	33	7583 Darlene St		236590-027	06/20/23		0.023
	10	2	7590 Lyncrest St		236590-004	06/13/23		0.024
	11	15	4065 Vermont Ln		236590-003	06/15/23		0.025
	12	23	2846 Crane Ave		236590-002	06/14/23		0.026
	13	30	5383 Kismet Ter		236590-022	06/14/23		0.027
	14	17	6550 Harmony Rd		236590-020	06/14/23		0.029
	15	55	5922 Hobhill Ave		236590-037	06/23/23		0.029
	16	43	6850 Higdon Rd		236590-030	06/22/23		0.030
	17	31	7554 Berwick St		236590-019	06/13/23		0.033
	18	1	7531 Berwick St		236590-024	06/19/23		0.033
	19	62	6690 Landover Ter		236590-008	06/21/23		0.034
	20	6	6691 Landover Ter		236590-006	06/16/23		0.039

CERTIFICATION. The tap samples used for lead and copper analyses were submitted by the above PWS. Each sample container had one liter of solution (± 100 mL). All samples were taken properly by the above system and analyzed in accordance with the requirements in subsection 62-550.550(1), F.A.C. The sampling dates were reported for each sample received. I hereby certify that all data submitted are correct.

SIGNATURE OF AUTHORIZED LABORATORY REPRESENTATIVE: _____ 

NAME (Please Print): _____ Tami Bright _____

TITLE and DATE: _____ Office Manager _____ 

Lead and Copper Tap Sample Analysis and Result Ranking

Reporting Format 62-550.730(4)(a)

System Name: North Port Utilities

Date Submitted to Lab: 06/21, 23, 27 - 2023

PWS-ID: 658-0651

Analysis Date: 06/26, 06/28, 07/01 - 2023

Laboratory Name: Pace Analytical

Lab Analysis method: EPA 200.8

Lab-ID: E83079

Lead or Copper (list one): Copper

Laboratory Contact Person:

Method Detection Limit: 0.00093 mg/L

Phone:

90th Percentile Value: 0.084

A	RANK	ID NO.	LOCATION	TIER	LAB SAMPLE ID	DATE SITE SAMPLED	LEAD (mg/L)	COPPER (mg/L)
	21	51	7505 Wexford St		236590-032	06/22/23		0.041
	22	27	4162 Corvette Ln		236590-005	06/15/23		0.043
	23	9	6138 Myrtlewood Rd		236590-021	06/14/23		0.043
	24	66	6220 Hoffman St		236590-031	06/21/23		0.045
	25	19	4072 Corvette Ln		236590-012	06/12/23		0.046
	26	3	5329 Ansonia Terr		236590-017	06/12/23		0.047
	27	63	4096 Alwick Ln		236590-007	06/21/23		0.048
	28	71	10415 Salford Blvd		236590-028	06/22/23		0.050
	29	13	1649 N Salford Blvd		236590-011	06/14/23		0.052
	30	64	3694 Bula Ln		236590-035	06/23/23		0.052
	31	40	4855 McCaughey Dr		236590-015	06/13/23		0.064
	32	35	3753 Aba Ln		236590-014	06/13/23		0.067
	33	47	3671 S Cranberry Blvd		236590-029	06/23/23		0.067
	34	77	6795 Appomattox		236590-023	06/23/23		0.084
	35	56	4298 Corvette Ln		236590-036	06/23/23		0.15
	36	8	7582 Berwick St		236590-018	06/13/23		0.16
	37	67	1539 Tripoli St		236590-026	06/22/23		0.19
	38	57	5052 Kingsley Rd		236590-038	06/23/23		0.26

CERTIFICATION. The tap samples used for lead and copper analyses were submitted by the above PWS. Each sample container had one liter of solution (± 100 mL). All samples were taken properly by the above system and analyzed in accordance with the requirements in subsection 62-550.550(1), F.A.C. The sampling dates were reported for each sample received. I hereby certify that all data submitted are correct.

SIGNATURE OF AUTHORIZED LABORATORY REPRESENTATIVE: _____ 

NAME (Please Print): _____ Tami Bright _____

TITLE and DATE: _____ Office Manager _____ 7/21/23